

INDUSTRIAL WASTE DISCHARGE PERMIT STANDARD CONDITIONS AND LIMITATIONS

- 1) **The permit holder** shall submit additional information on industrial waste or storm water discharges as required by the City Engineer.
- 2) **The permit holder** shall keep all liquid industrial waste and water soluble solid waste not acceptable for discharge into the public sanitary sewer system stored in leak proof containers pending transportation to a legal point of disposal. The permittee shall certify the source, quantity, and point of disposal by certifying a Uniform Hazardous Waste Manifest.
- 3) **The permit holder** shall keep copies of the completed Uniform Hazardous Waste Manifest on file for a period of at least 180 days for any waste transport from the site. The manifest shall be made available to representatives of the City Engineer upon request.
- 4) **The permit holder** shall conduct waste disposal operations in such a manner that no nuisance is created.
- 5) **The permit holder** shall adopt a routine cleaning and maintenance program to prevent the build-up of oil and grease, sludge and other deleterious materials in pretreatment facilities, including clarifiers, interceptors and sample boxes, to prevent the discharge of these materials into the sanitary sewer and storm drain systems.
- 6) **The permit holder** shall allow representatives of interested governmental agencies concerned with the disposal of industrial waste access at any reasonable time to collect samples and inspect operations and equipment.
- 7) **The permit holder** shall secure written approval from the City Engineer before making any additions or modifications which may affect the quantity, quality, or method of disposal of waste materials.
- 8) **The permit holder** shall install all required industrial waste and storm water collection treatment and disposal facilities prior to initiation of any discharge.
- 9) **The permit holder** shall install additional pretreatment facilities if inspections indicate that prohibited materials are being discharged.
- 10) **The permit holder** shall pay an annual industrial waste inspection fee.
- 11) **This permit** is subject to suspension or revocation if conditions exist which would justify denial of a permit or if the permittee fails to correct unsatisfactory conditions.
- 12) **In the event of any change of ownership**, name, control or legal abandonment of the waste disposal facilities, the permittee shall notify the City Engineer of such change. The permittee shall also notify the succeeding owner or operator of the existence of this permit by letter, a copy of which shall be forwarded to the City Engineer.
- 13) **Hazardous waste or materials** which would cause the contents of the sanitary sewer or storm drain system to become hazardous are not permitted to be discharged to the sanitary sewer or storm drain system. Such discharge is grounds for revocation of this permit.
- 14) **The City Engineer may modify this permit** by addition, revision, or elimination of conditions and limitations as may be necessary to accomplish the purpose of ordinances and laws covering disposal of waste materials.

SANITARY SEWER DISCHARGE LIMITATIONS	
PARAMETER	MAXIMUM ALLOWABLE CONCENTRATIONS AT ANY TIME (mg/L)
Cyanide (total)	10
Arsenic	3
Cadmium	15
Chromium (total)	10
Copper	15
Lead	40
Mercury	2
Nickel	12
Silver	5
Zinc	25
*TIC	Essentially None
Oil and Grease	None Visible – with Maximum Concentration of 75
pH	6 – 12.5 (or lower range if scaling occurs)
Langelier's Index	2
Flash Point	Over 140°
Temperature	140°
Food Particles	Less than 3/8" in diameter
Additional constituents including suspended solids, total dissolved solids (TDS), thiosulfate, ammonia, benzene, mercaptans, fluoride, surfactants and toxic organics are subject to restriction.	

* - Total Identifiable Chlorinated Hydrocarbons includes such compounds as aldrin, dieldrin, chlordane, DDT, endrin, hexachlorocyclohexane, toxaphene and PCB's.

The Sanitation Districts of Los Angeles County may impose more stringent discharge limits, the most stringent limit must be complied with.

APPLICANT INITIALS